

WP 497/MK/BE

Firma  
KLINGER Fluid Control GmbH & Co KG

Am Kanal 8-10  
A-2352 Gumpoldskirchen

## FIRE TEST CERTIFICATE

This is to certify that the following ball valves KLINGERballostar-I have satisfactorily passed the Fire Safe Test according to

API 607 Fourth Edition, May 1993

KLINGERballostar-I Type KHI, KHSVI, KHSVWI								
Item No	TUV Test report	Date of test	Klinger firesafe test	Valve tested size PN type			Valve sizes qualified	PN rating qualified
1	WP 181/MK/BE	20 12 1999	Hc- 276	200	40	KHI	DN150, DN 200 DN 250 DN 300 DN 350 DN 400 DN 500, DN 600, DN 700, DN 800	PN16, PN25, PN40

Valves tested in	Material qualified for soft seated ball valves
1 0619 (GP240GH) / A 216 WCB	ASME/ANSI B16 34-1988 Table 1

Date 22 03 2000

  
 Surveyor to TÜV-Austria  
 Ing Matzik