



Inspection Certificate

Project: ---

Client: **Klinger Fluid Control GmbH
Gumpoldskirchen / Austria**

Office: **Dortmund**

Clients Order Number: ---

Date: **17 January 2008**

Order Status: **incomplete**

Inspection Dates

First: **06 December 2007**

Final: **21 December 2007**


This certificate is issued to the above client to certify that a surveyor to Lloyd's Register did, at their request, attend the testing laboratory of Dr.-Ing. T. Bäumer – Ingenieurbüro -, Herford / Germany for the purpose of inspecting the product listed below.

Description:	Flame resistant test of -1- Ball Valve	
Type:	KHI	
Nominal bore:	DN 150	
Pressure rating:	PN 25	
Manufacturer's drawing:	wUH890/2.0-0000	
Materials:	Body/flange end piece material:	1.0619
	Operating stem material:	1.4104
	Ball material:	0.7040
	Sealing elements:	X-AF-Metal (Stellite 12)
	Stem seal material:	O-Ring (FEPM, FPM)
Test requirements:	DIN EN ISO 10497, 2004 and API 607, 5th edition	
Qualified pressure ratings:	Class 150 / Class 300	

The flame resistance tests have been carried out at the independent laboratories of Dr.-Ing. Bäumer.

Conclusion: All test results, witnessed by the Lloyd's Register Surveyor, were found to be satisfactory and fulfil the requirements of DIN EN ISO 10497, 2004 in every respect.
For details please refer to the attached signed and stamped test reports (4 pages).

Remarks: Ball valve DN 150 pressure rating PN 25 also covers DN 150 and below, DN 200, DN 250 and DN 300.



For G. Milke: K. Allermann
Surveyor to Lloyd's Register EMEA

A member of the Lloyd's Register Group

E&T/PRu

Lloyd's Register, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register Group'. The Lloyd's Register Group assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register Group entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

TEST Report

Flame - resistance tests according to DIN EN ISO 10497 Report Hc-418

This report confirms the successful testing of a representative valve in compliance with the DIN EN ISO 10497, 2004.

Manufacturer	Klinger Fluid Control GmbH Am Kanal 8 - 10 A - 2352 Gumpoldskirchen
Test Valve	Ball -Valve, KHI, flange end connections, Gear operated Nominal bore: DN 150 Pressure rating: PN 25 Weight: 115 kg Bore: Full bore Body/flanged end piece material: 1.0619 Operating stem material: 1.4104 Ball material: 0.7040 Sealing elements: X-AF-Metall (Stellit 12) Stem seal material: O-Ring (FEPM, FPM) Drawing number: wUH890/2.0-0000 Operation device: Gear AUMA GS 80.3
Date of Testing	06 December 2007
Test Report	7 pages
Qualified sizes	DN 150, DN 200, DN 250, DN 300
Qualified pressure ratings	Class 150, Class 300 PN 25, PN 40
Testing location	Laboratory of consultant engineer Dr.-Ing. T. Bäumer, Altensenner Weg 75, D - 32052 Herford
Test requirements	The tests were carried out strictly in accordance with DIN EN ISO 10497, 2004 and API 607, 5th edition
Participants	Mr. G. Milke Lloyds Register, EMEA Mr. Dr. T. Bäumer Ingenieurbüro Dr.-Ing. T. Bäumer

Test examination

The water filled ball valve was subjected to fire for 30 minutes at a temperature between 750 °C and 1000 °C and a pressure of e.g. 18,75 barg. After the burn period the through-seat-leakage was determined and after a cool down period the external leakage was measured. Then the ball valve was opened, and the external leakage was determined.

Instrumentation

Temperature: 4 Thermocouples, Ni Cr Ni, accuracy 1 K.

Pressure: Pressure transmitter, accuracy 0,5 %.

PC-system: AD converter board, software for measuring, Personal Computer

The measuring devices are controlled by an accredited calibration service.

Body cavity set relief pressure and setting: 37,5 barg

Test results

Time of test start (ignition of burners): 9.55 a.m.

Temperatures and pressure during burn period

Time	p	T _{Fire1}	T _{Fire2}	T _{Cal1}	T _{Cal2}
[s]	[barg]	[°C]	[°C]	[°C]	[°C]
.00	18.79	419.0	404.9	11.9	8.0
30.00	18.79	596.0	536.1	15.9	12.4
60.00	18.79	736.9	684.4	22.9	33.9
90.00	18.79	807.4	802.2	36.9	37.2
120.00	18.79	819.0	808.4	53.9	42.1
150.00	18.79	833.9	822.9	67.4	52.4
180.00	18.79	792.6	865.0	131.9	103.2
210.00	18.79	798.2	876.1	191.9	151.4
240.00	18.79	869.9	899.4	250.4	217.3
270.00	18.79	984.4	960.2	311.9	280.4
300.00	18.79	961.9	997.4	373.4	344.9
330.00	18.79	986.6	993.4	424.4	401.9
360.00	18.79	990.7	973.9	461.9	452.9
390.00	18.79	963.4	901.4	484.4	497.9
420.00	18.79	922.6	748.2	505.4	518.9
450.00	18.79	840.1	817.3	520.4	538.4
480.00	18.79	831.4	775.4	524.9	553.4
510.00	18.79	903.3	979.2	533.9	577.4
540.00	18.79	877.2	972.4	548.9	601.4
570.00	18.79	857.9	975.4	559.4	619.4
600.00	18.79	853.8	982.9	569.9	634.4
630.00	18.79	853.8	981.6	578.9	647.9
660.00	18.79	875.8	850.8	589.4	661.4

690.00	18.79	911.6	937.4	598.4	670.4
720.00	18.79	945.9	974.9	610.4	682.4
750.00	18.79	934.9	941.1	620.9	689.9
780.00	18.79	936.3	980.9	629.9	697.4
810.00	18.79	937.7	961.4	646.4	710.9
840.00	19.09	945.9	985.7	658.4	721.4
870.00	19.25	944.6	964.4	665.9	728.9
900.00	18.94	954.2	985.3	671.9	736.4
930.00	18.87	895.1	874.4	674.9	739.4
960.00	18.87	851.1	847.1	674.9	737.9
990.00	18.79	835.9	785.9	670.4	733.4
1020.00	18.79	879.9	848.9	668.9	734.9
1050.00	18.79	877.2	860.9	670.4	737.9
1080.00	18.87	863.4	811.4	670.4	740.9
1110.00	18.87	844.2	785.9	665.9	742.4
1140.00	18.87	842.8	779.9	661.4	742.4
1170.00	18.79	829.1	758.9	656.9	742.4
1200.00	18.79	811.2	748.4	669.4	740.9
1230.00	18.49	885.4	937.4	663.4	740.9
1260.00	18.72	904.7	983.9	664.9	746.9
1290.00	18.79	893.7	953.9	666.4	752.9
1320.00	18.87	919.8	895.4	669.4	757.4
1350.00	18.35	889.6	875.9	658.4	760.4
1380.00	18.35	817.8	813.9	655.4	748.4
1410.00	18.35	816.8	818.4	654.4	722.9
1440.00	18.35	823.2	824.4	654.4	694.4
1470.00	18.35	817.8	822.4	667.9	690.4
1500.00	18.35	821.8	822.4	658.9	685.4
1530.00	18.87	867.6	875.9	655.9	698.9
1560.00	19.17	900.6	872.9	667.4	690.9
1590.00	18.64	906.1	907.4	657.9	692.9
1620.00	18.79	906.1	901.4	666.9	703.4
1650.00	18.72	912.9	922.4	655.9	715.4
1680.00	18.64	911.6	902.9	663.4	725.9
1710.00	18.72	900.6	866.9	652.4	731.9
1740.00	18.72	926.7	935.9	658.4	734.9
1770.00	18.79	923.9	889.4	665.9	740.9
1800.00	18.75	889.6	875.9	658.4	760.8

Time required for valve to cool down to 100 °C: 9 min

Test valve unseated: Yes

Test valve moved to the fully open position: Yes

ATTACHMENT TO LLOYD'S
REGISTER CERT. NO. DTM

	Leakage [ml/DN/min]	Allowable leakage [ml/DN/min]
Through-seat-leakage in burning phase:	0,6	4,0
External leakage in burning and cooling phase:	0,0	1,0
Through-seat-leakage at low pressure:	0,3	1,6
External leakage in the open position:	0,0	1,0

Comments on the results

The test valve is an asymmetric ball valve. Because it is intended for one-directional installation, the tests were carried out only for one flow direction.

Conclusion

The test valve fulfilled the test requirements according to DIN EN ISO 10497, 2004. Only allowable through-seat-leakages and external leakages were observed during the test.

Herford, 06 December 2007

Lloyd's Register
EMEA


Lloyd's Register EMEA

Business Centre Central
Dortmund

Lloyd's
Register

Mr. G. Milke
Surveyor

Dr.-Ing. T. Bäumer
Ingenieurbüro



Mr. Dr. T. Bäumer
Consultant engineer

ATTACHMENT TO LLOYD'S
REGISTER CERT. NO. DTM

0712264/1